0034190 DATA SHEET

valid from: JE-Y(ST)Y...BD



Application

JE-Y(ST)Y...BD is a connecting cable for industrial electronics. It can be used in measurement and control engineering and also as pulse and data transmission cable.

The cable is intended for use in dry and damp interiors and for fixed installation.

Design

Outer sheath

Design acc. to DIN VDE 0815, Table 4

Type JE-Y(ST)Y...BD

Certification Classification of fire behaviour

according to EN 13501-6 and EN 50575

(article/dimension range see www.lappkabel.com/cpr)
Colour of the sheath: pebble grey (similar RAL 7032)

Electrical properties at 20 °C

 $\begin{array}{lll} \mbox{Loop resistance} & \mbox{max. 73.2 } \ensuremath{\Omega/km} \\ \mbox{Insulation resistance} & \mbox{min. 100 M} \ensuremath{\Omega/km} \\ \end{array}$

Mutual capacitance max. 100 nF/km (at 800 Hz)

Inductance ca. 0.65 mH/km

Capacitive coupling max. 200 pF/100 m (at 800 Hz)

Maximum operating voltage 225 V (not for power applications)

Must not be connected to the mains supply voltage.

Test voltage C/C: 500 V

C/S: 2000 V

Mechanical and thermal properties

Minimum bending radius fixed installation: 6 x outer diameter

Temperature range occasional flexing: -5 °C up to +50 °C max. conductor temperature

fixed installation: -30 °C up to +70 °C max. conductor temperature

Flammability flame retardant acc. to EN 60332-1-2 resp. IEC 60332-1-2

Tests acc. to DIN VDE 0815, Type JE-Y(ST)Y...BD

Electrical properties acc. to table 10 Tests at the cable acc. to table 21

General requirements These cables are conform to

EU-Directive 2014/35/EU (Low Voltage Directive) and to EU-Directive 2011/65/EU (RoHS, Restriction of the use of certain

hazardous substances).

These cables (see www.lappkabel.com/cpr) are classified in accordance with the EU-Regulation no. 305/2011 (CPR).

Environmental information These cables meet the substance-specific requirements of the EU Directive 2011/65/EU (RoHS).

Note Trade product, no Lapp product

Creator: PESA / PDC Document: DB0034190EN

Released: ALTE / PDC Version: 06

Page 1 of 1